



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2021 T/J(1482/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

28 December 2021

**Approval of "EC-LOK" Stainless Steel Pipes
(General Acceptance No. C20211451)**

Your letter ref. 30006/WSD/SUB-5/01 dated 24 September 2021 and subsequent submissions received by this department up to 6 December 2021 refer.

Having considered the test report ref. J25778A-Fr3 issued on 2 December 2021 by Nutek Systems (HK) Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: YC Inox

Country of Origin: Taiwan, China

Brand: EC-LOK

Details of Pipes: Stainless steel pipes - Series 2 (304)

Size: 15mm, 22mm, 28mm, 35mm, 42mm, 54mm

Body Markings: EC-LOK 10312 1.4301 size x thickness x length
Heat no. XXXXXX YC

Expiry Date: 6 July 2026



This Authority hereby permits the use of the above pipes in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only