



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1796/2021)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

19 January 2022

**Approval of "TECE" Float Operated Valves  
(General Acceptance No. C20220062F)**

Your letters ref. 2021/TECETECH/1205/0013/L and  
2021/TECETECH/1228/0016/L dated 5 December 2021 and 28 December 2021  
respectively refer.

Having considered the test report ref. J27167 issued on 7 December 2021 by  
Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below  
comply with, and their use when correctly installed does not contravene, the  
Waterworks Ordinance and Regulations.

**Name of Manufacturer:** TECE GmbH  
**Country of Origin:** Germany  
**Brand:** TECE  
**Details of Fitting:** Plastic float operated valve  
**Model:** CN00590100  
**Size:** 3/8", 1/2"  
**Body Markings:** TECE:

**Expiry Date:** 24 November 2026

**Proviso:** As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The flushing volume of the flushing valve should be adjusted to suit the design of the toilet bowl so that wastes can be cleared effectively by a single flush."

"The maximum flushing cistern volume including that of dual flush cisterns for use in conjunction with the fittings shall not exceed 7.5 litres per flush."

"The fittings should be used within the range of working pressures specified by the manufacturer." AND

"The installed fittings should not result in backflow of water that will contaminate the flushing water supply."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only

---

**General Acceptance No. C20220062F**



CN00590100