



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1723/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

10 February 2022

**Approval of "ECFIT" Copper Fittings
(General Acceptance No. C20220118)**

Your letters ref. TCWI Approval-001 and TCWI Approval-002 dated 23 November 2021 and 6 January 2022 respectively refer.

Having considered the test reports ref. 212654PC210178(7)B, 212654PC210178(8), 212654PC210178(5)B and 212654PC210178(6)B all issued on 4 January 2022 & ref. 212654EN211930(3) issued on 21 October 2021 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Taizhou Xinhan Sanitary Co Ltd

Country of Origin: the Mainland of China

Brand: ecFIT

Details of Fittings: Copper alloy fittings with solder ring connection ends

Description	Model	Size
Solder Ring Male Coupling	TC302	15x½", 22x¾", 28x1", 35x1¼", 42x1½", 54x2" (mm x inch)
Solder Ring Female Coupling	TC303	15x½", 22x¾" (mm x inch)

Description	Model	Size
Solder Ring Female Reducer	TC303	22x½" (mm x inch)
Solder Ring Male 90° Elbow	TC402	15x½" (mm x inch)
Solder Ring Female 90° Elbow	TC403	15x½", 22x½", 22x¾" (mm x inch)
Solder Ring Wall Plate	TC453	15x½" (mm x inch)
Solder Ring Female Tee	TC617	15x15x½", 22x22x½" (mm x mm x inch)

Body Markings: ecFIT EN1254-1

Expiry Date: 31 August 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,




(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Solder Ring Female Coupling



Solder Ring Male Coupling



Solder Ring Female Reducer



Solder Ring Female 90° Elbow



Solder Ring Female Tee



**Solder Ring Male 90°
Elbow**



Solder Ring Wall plate