



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(7/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

22 February 2022

**Approval of "DECO" Copper Fittings
(General Acceptance No. C20220145)**

Your letters both ref. SL20211224-1 dated 24 December 2021 and 18 January 2022 refer.

Having considered the test report ref. BC-SUMMARY-2021-201 issued on 10 December 2021 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhejiang Hailiang Co Ltd

Country of Origin: the Mainland of China

Brand: Deco

Details of Fittings: Copper alloy fittings with end feed connection ends

Description	Model	Size (mm x inch)
Male Coupler	DEW302	67x2½", 76x3", 108x4"
Female Coupler	DEW303	67x2½", 76x3"

Body Markings: BS EN 1254 (DN) mm



Expiry Date: 8 December 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



DEW302



DEW303