



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(9/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

10 March 2022

**Approval of "SINOTEC" Gate Valves
(General Acceptance No. C20220178)**

Your letters ref. 108/2022, 206/2022 and 237/2022 dated 5 January 2022, 7 February 2022 and 21 February 2022 respectively refer.

Having considered the test report ref. PMA92140A issued on 8 July 2019 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yantai Valve Factory

Country of Origin: the Mainland of China

Brand: Sinotec

Details of Fittings: Ductile iron resilient seated gate valve with epoxy powder coating under WRAS approval no. 2008501

Model: BZ45X-16B

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

Body Markings: SINOTEC BS5163-1 EN1074-2 year of manufacture
size in DN PN16 SG RES

Expiry Date: 27 June 2024

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



BZ45X-16B