



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(1621/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

18 March 2022

**Approval of “VALMATIC” Check Valves
(General Acceptance No. C20220207)**

Your letters ref. GWL/21/1101 and GWL/21/1101-1 dated 1 November 2021 and 2 March 2022 respectively refer.

Having considered the test report ref. BC-SUMMARY-2021-150 issued on 7 January 2022 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Val-Matic Valve & Manufacturing Corp

Country of Origin: the Mainland of China

Brand: Valmatic

Details of Fitting: Cast iron wafer type silent check valve with epoxy powder coating under WRAS approval no. 2202530

Model and Size: 1402AHKXF - 50mm
1425AHKXF - 65mm
1403AHKXF - 80mm
1404AHKXF - 100mm



1406AHKXF - 150mm
1408AHKXF - 200mm

Body Markings: VAL MATIC CORP

Expiry Date: 28 September 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



1402AHKXF / 1425AHKXF /
1403AHKXF / 1404AHKXF /
1406AHKXF / 1408AHKXF /