



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(22/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

21 March 2022

**Approval of “ANCHOR” UPVC Pipes
(General Acceptance No. C20220214F)**

Your letters dated 6 January 2022, 20 January 2022 and 14 February 2022 refer.

Having considered the test report ref. J27426A-Jr1 issued on 14 February 2022 by Nutek Systems (HK) Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhongshan Universal Enterprise Ltd

Country of Origin: the Mainland of China

Brand: Anchor

- Details of Pipes:**
1. uPVC pipes in white colour (Class E)
Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm
 2. uPVC pipe in white colour (Class D)
Size: 150mm



Body Markings:

Nominal Size (mm)	Body Marking
15	通过 ISO 9001 体系认证  BVP15 BS3505 E 15 mm 26
20	通过 ISO 9001 体系认证  BVP20 BS3505 E 20 mm 27
25	通过 ISO 9001 体系认证  BVP25 BS3505 E 25 mm 30
32	通过 ISO 9001 体系认证  BVP32 BS3505 E 32 mm
40	通过 ISO 9001 体系认证  BVP40 BS3505 E 40 mm
50	通过 ISO 9001 体系认证  BVP50 BS3505 E 50 mm
65	通过 ISO 9001 体系认证  BVP65 BS3505 E 65 mm
80	通过 ISO 9001 体系认证  BVP80 BS3505 E 80 mm
100	通过 ISO 9001 体系认证  BVP100 BS3505 E 100 mm
150	通过 ISO 9001 体系认证  BVP150 BS3505 D 150 mm

Expiry Date: 21 December 2026

Proviso: As the pipes have not been tested for use in contact with water intended for human consumption, the pipes can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above pipes in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in flushing water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

General Acceptance No. C20220214F