



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(198/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

28 March 2022

**Approval of "CNB" Globe Valves
(General Acceptance No. C20220237)**

Your letters ref. WSD/AP-09122021-1 and WSD/AP-09122021-1(1) dated 24 February 2022 and 11 March 2022 respectively refer.

Having considered the test report ref. 184411PC210326(1)B issued on 22 December 2021 by Fugro Technical Services Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: CNB (Far East) Ltd

Country of Origin: Taiwan, China

Brand: CNB

Details of Fittings: Cast iron globe valve with epoxy coating under WRAS approval no. 2104506

Model: CN650S

Size: 65mm, 80mm, 100mm, 150mm, 200mm

Body Markings: size in DN size in inch BS5152 CNB PN16 ➡



Expiry Date: 30 April 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



CN650S