



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(206/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

26 April 2022

**Approval of "SHIN NAN" Ductile Iron Pipes
(General Acceptance No. C20220315)**

Your letters ref. 248/2022 and 438/2022 dated 23 February 2022 and 12 April 2022 respectively refer.

Having considered the test report ref. PMA20366 issued on 19 January 2022 by ETS-Testconsult Limited and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shin Nan Casting Factory Co Ltd

Country of Origin: Taiwan, China

Brand: Shin Nan

Details of Pipes: K12 Ductile iron socket and spigot pipes with internal cement lining under WRAS approval no. 1906578

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm

Body Markings: BSEN545  Shin Nan 2021
D.I. class K12 size x length

Expiry Date:

30 June 2024

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only