



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(291/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

8 June 2022

**Approval of “VINIDEX” UPVC Pipes
(General Acceptance No. C20220487)**

Your letters dated 22 March 2022, 27 April 2022 and 10 May 2022 refer.

Having considered the test reports ref. BC-SUMMARY-2022-009 and 211102-2412 issued on 26 January 2022 and 24 January 2022 by Castco Testing Centre Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Lifan Plastics Co Ltd

Country of Origin: the Mainland of China

Brand: Vinidex

Details of Pipes: uPVC pipes in white colour (Class E)

Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm

Body Markings: Vinidex UPVC (Size) BS3505 CLASS E

Expiry Date: 15 October 2026

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no: 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only