



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(500/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

23 June 2022

**Approval of “VANZON” Gate Valves
(General Acceptance No. C20220552)**

Your letters ref. C3687/WSD/JN376 and C3709/WSD/JN376 dated 3 May 2022 and 28 May 2022 respectively refer.

Having considered the test report ref. J27564A-Fr1 issued on 26 May 2022 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Ningbo Yinzhou Tiancheng Nonferrous Metal Foundry

Country of Origin: the Mainland of China

Brand: Vanzon

Details of Fittings: Copper alloy gate valve

Model and size:
AGV(s)-020 - 20mm
AGV(s)-025 - 25mm
AGV(s)-040 - 40mm
AGV(s)-050 - 50mm
AGV(s)-080 - 80mm
AGV(s)-100 - 100mm

Body Markings: Size in inch PN20 BS5154 CC491K VANZON

Expiry Date: 11 April 2027

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,




(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



AGV(s)-020 / AGV(s)-025 / AGV(s)-040 /
AGV(s)-050 / AGV(s)-080 / AGV(s)-100