



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(426/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

13 July 2022

**Approval of "COOPER & GRAHAM" Bath Mixer
(General Acceptance No. C20220641)**

Your letter ref. D73A/D2022/0335 dated 11 April 2022 and subsequent submissions received by this department up to 16 June 2022 refer.

Having considered the test report ref. 211801PC210097 issued on 25 March 2022 by Fugro Technical Services Limited and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shenzhen Globe Union Enterprise Co Ltd

Country of Origin: the Mainland of China

Brand: Cooper & Graham

Details of Fitting: 1/2" Deck mounted three holes bath mixer with 2 nos. of flexible hoses approved by UK's WRAS under ref. 1901522

Model: ADE-11250.14-XX + OAN-20475.14
(where "XX" denotes the variation in finishes)

Body Markings:



Hong Kong Awards for Environmental Excellence



Expiry Date:

31 January 2024

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



ADE-11250.14-XX + OAN-20475.14