



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(550/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

15 July 2022

**Approval of "LEDE" Strainers
(General Acceptance No. C20220650)**

Your letters dated 12 May 2022 and 27 June 2022 refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
LEDE	6101 (50mm)	J23696Ar6	10 May 2022
LEDE	6101 (65mm)	J23696Br6	10 May 2022
LEDE	6101 (80mm)	J23696Cr6	10 May 2022
LEDE	6101 (100mm)	J23696Dr6	10 May 2022
LEDE	6101 (150mm)	J23696Er6	10 May 2022
LEDE	6101 (200mm)	J23696Fr6	10 May 2022

Having considered the above test reports issued by the Nutek Systems (HK) Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shandong LEDE Machinery Co Ltd

Country of Origin: the Mainland of China

Brand: LEDE

Details of Fitting: Ductile iron Y-strainer with epoxy coating under WRAS approval no. 2104506

Model: 6101

Size: 50mm, 65mm, 80mm, 100mm, 150mm, 200mm

Body Markings: LEDE size in DN PN16 EN-JS1050 6101 2018

Expiry Date: 16 December 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



6101