



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 4 ) in WSD 3321/2022 T/J(667/2022)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

19 July 2022

**Approval of "TOTO" Sensor Taps  
(General Acceptance No. C20220663)**

Your letters ref. L-TT-8777 and L-TT-8797 dated 7 June 2022 and 29 June 2022 respectively refer.

Having considered the test reports ref. 220299PC220046A and 201726EN203153 issued on 20 June 2022 and 4 March 2021 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** TOTO (Shanghai) Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** TOTO

**Details of Fitting:** 1/2" Deck mounted sensor tap with 1 no. of flexible hose

**Model:** DLE110A2N#XXX + DLE124DH  
DLE110A2N#XXX + DLE124DE  
(where "XXX" denotes the code of colour)

**Body Markings:** **TOTO**

**Expiry Date:**

23 February 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only



DLE110A2N#XXX+DLE124DH /  
DLE110A2N#XXX+DLE124DE