



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (13) in WSD 3321/2021 T/J(1445/2021)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

21 July 2022

**Approval of “KD” Float Valves
(General Acceptance No. C20220674)**

Your letter dated 7 September 2021 and subsequent submissions received by this department up to 4 July 2022 refer.

Having considered the test reports ref. RLMC002Ar1, RLMC002Br1, RLMC002Cr1 and RLMC001Dr1 all issued on 29 October 2021 by Ideal Test Consultants Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Guo Yu Hardware Company Limited

Country of Origin: the Mainland of China

Brand: KD

Details of Fittings: Stainless steel equilibrium type float valve

Model and Size:

FW 1-1/2	- 40mm
FW 2	- 50mm
FW 3	- 80mm
FW 4	- 100mm

Body Markings: KD

Expiry Date: 9 August 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,





(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



FW 1-1/2 / FW 2 /
FW3 / FW 4