



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (12) in WSD 3321/2022 T/J(153/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

26 July 2022

**Approval of “NUPI” PE Pipes
(General Acceptance No. C20220700)**

Your letter dated 7 February 2022 and subsequent submissions received by this department up to 28 June 2022 refer.

Having considered the test reports ref. RT2200373B issued on 24 June 2022 by The Lab (Asia) Ltd. and ref. 211103-2728 issued on 20 January 2022 by Castco Testing Centre Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: NUPI Industrie Italiane SPA
Country of Origin: Italy
Brand: NUPI
Details of Pipes: PE pipes in black colour (PE100, SDR11)
Size: 32mm, 50mm, 63mm

Body Markings:

Nupi Nadir Plus BS EN12201 ISO4427 BS6920
DN/OD x wall thickness PN16 SDR 11
PE100 WATER B94H Batch No.

Expiry Date:

19 November 2026

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only