



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 4 ) in WSD 3321/2022 T/J(516/2022)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

4 August 2022

**Approval of “TRM CHINA” Ductile Iron Pipes  
(General Acceptance No. C20220737)**

Your letters dated 6 May 2022 and 27 June 2022 refer.

Having considered the test report ref. PMA22041 issued on 25 April 2022 by ETS-Testconsult Limited and WRAS certificates, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Guoming Ductile Iron Pipes Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** TRM China

**Details of Pipes:** K9 Ductile iron socket and spigot pipe with internal epoxy seal coat (under WRAS approval no. 1807559) for cement mortar lining (under WRAS approval no. 1910534)

**Size:** 200mm, 250mm, 300mm, 400mm

**Body Markings:** TRM China BSEN545 K9 size in DN L=6000mm



**Expiry Date:** 31 July 2023

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only