



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2022 T/J(1000/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

2 September 2022

**Approval of “DECO” Long Screw Connector
(General Acceptance No. C20220820)**

Your letter ref. SL20220829-1 dated 29 August 2022 refers.

Having considered the test report ref. BC-SUMMARY-2022-069 issued on 27 June 2022 by Castco Testing Centre Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yuhuan Dahua Valve Co Ltd
Country of Origin: the Mainland of China
Brand: Deco
Details of Fitting: Copper alloy long screw connector
Model: LAAD631GM-038
Size: 1½"
Body Markings: DECO

Expiry Date:

15 June 2027

This Authority hereby permits the use of the above fitting only at temporary mains fresh water for flushing (TMF) position for connection of water meter subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed should be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply system mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



LAAD631GM-038