



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(785/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

2 September 2022

**Approval of “TEGA” PE Fittings
(General Acceptance No. C20220823)**

Your letters dated 2 July 2022, 28 July 2022 and 10 August 2022 refer.

Having considered the test reports ref. PMA22361A, PMA22362A and PMA22363A issued on 10 August 2022 by ETS-Testconsult Limited and WRAS approval no. 1806511, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: TEGA Muhendislik Sanayi Ve Tic AS

Country of Origin: Turkey

Brand: TEGA

Details of Fittings: PE fittings in black colour (PE100, SDR11)

Description	Size (mm)
Electrofusion Elbow 90°	32, 50, 63, 90
Electrofusion Equal Tee	32, 50, 63, 90
Electrofusion Reducer	50x32, 63x32, 90x63



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



Body Markings:



Nominal size PE100 SDR11

Expiry Date:

30 June 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,

A handwritten signature in black ink, appearing to read "YAU Hau Yin", written over a horizontal line.

(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Electrofusion Equal Tee



Electrofusion Reducer



Electrofusion Elbow 90°