



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(677/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

14 September 2022

**Approval of “WAH CHIT” Galvanized Steel Pipes
(General Acceptance No. C20220855FS)**

Your letters ref. L221004 and L221005 dated 8 June 2022 and 14 July 2022 respectively refer.

Having considered the test reports ref. J26550A, J26550B, J26550C and J26550D all issued on 6 October 2021 by Nutek Systems (HK) Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangdong Walsall Steel Pipe Industrial Co Ltd

Country of Origin: the Mainland of China

Brand: Wah Chit

Details of Pipes: Galvanized steel pipes

Size: 200mm, 250mm, 300mm, 350mm

Body Markings:  WAH CHIT Size in DN O.D x Length EW
BSEN10217-1 Production Code

Expiry Date: 4 July 2026

Proviso: The pipes can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Mable LH LAM)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only