



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(887/2022)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

20 September 2022

**Approval of “SEAH” Galvanized Steel Pipes  
(General Acceptance No. C20220873FS)**

Your letters dated 28 July 2022 and 7 September 2022 refer.

Having considered the test reports ref. BC-SUMMARY-2022-079 and BC-SUMMARY-2022-080 both issued on 11 July 2022 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** SeAH Steel Vina Corporation

**Country of Origin:** Vietnam

**Brand:** SeAH

**Details of Pipes:** Galvanized steel pipe (class medium and heavy)

**Size:** 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm

**Body Markings:**

For class medium:

SčAH SeAH Steel EN10255 SERIES MEDIUM W  
size x length MADE IN VIETNAM  
KHK Batch no. VN

For class heavy:

SčAH SeAH Steel EN10255 SERIES HEAVY W  
size x length MADE IN VIETNAM  
KHK Batch no. VN

**Expiry Date:**

4 July 2027

**Proviso:**

The pipes can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only