



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(885/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

30 September 2022

**Approval of “WEIXING” PE Pipes
(General Acceptance No. C20220922)**

Your letters dated 26 July 2022 and 5 September 2022 refer.

Having considered the test reports ref. PMA10039 and AGA20385 issued on 19 January 2021 and 22 July 2022 by ETS-Testconsult Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhejiang Weixing New Building Materials Co Ltd

Country of Origin: the Mainland of China

Brand: Weixing

Details of Pipes: PE pipes in black colour (PE100, SDR11)

Size: 25mm, 32mm, 40mm, 50mm, 63mm, 75mm, 90mm, 125mm, 180mm, 225mm, 250mm, 315mm

Body Markings: WEIXING PE100 SDR11 PN16
DN/OD x Wall thickness BSEN12201 Production date

Expiry Date: 26 November 2025

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only