



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (12) in WSD 3321/2022 T/J(886/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

31 October 2022

**Approval of “WEIXING” PE Fittings
(General Acceptance No. C20221016)**

Your letter dated 26 July 2022 and subsequent submissions received by this department up to 17 October 2022 refer.

Brand	Type of Fittings	ETS Test Report Ref.	Issuance Date
Weixing	PE Fittings - Bend	PMA10040	19 January 2021
Weixing	PE Fittings - Tee	PMA10041A	11 March 2021
Weixing	PE Fittings - Reducer	PMA10042B	5 September 2022

Having considered the above test reports and ref. AGA20385 issued on 22 July 2022 by ETS-Testconsult Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhejiang Weixing New Building Materials Co Ltd

Country of Origin: the Mainland of China

Brand: Weixing

Details of Fittings: PE fittings in black colour (PE100, SDR11)

Description	Size (mm)
E.F. Elbow 45°	32, 40, 50, 63, 90, 125, 180, 225, 250, 315
E.F. Elbow 90°	25, 32, 40, 50, 63, 75, 90, 125, 180, 225, 250, 315
S.F. Elbow 45°	25, 32
S.F. Elbow 90°	25, 32
E.F. Equal Tee	25, 32, 40, 50, 63, 90, 125, 180, 250
E.F. Reducing Tee	32x25x32, 40x32x40, 50x32x50, 63x32x63, 63x50x63, 90x50x90, 90x63x90, 125x63x125, 125x90x125, 180x125x180, 250x180x250
S.F. Equal Tee	25, 32
S.F. Reducing Tee	32x25x32
E.F. Reducer	32x25, 40x32, 50x32, 50x40, 63x32, 63x40, 63x50, 90x50, 90x63, 125x63, 125x90, 180x125, 250x180
S.F. Reducer	32x25

Body Markings: 伟星® Nominal size PE SDR11

Expiry Date: 7 December 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

General Acceptance No. C20221016



E.F. Elbow 90°



E.F. Elbow 45°



E.F. Elbow Tee



E.F. Reducing Tee



E.F. Reducer



S.F. Elbow 45°



S.F. Elbow 90°



S.F. Tee



S.F. Reducer



S.F. Reducing Tee