



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(1003/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

1 November 2022

Approval of "KC" UPVC Pipes
(General Acceptance No. C20221021)

Your letters dated 26 August 2022 and 14 October 2022 refer.

Having considered the test report ref. 02080W200009-1 issued on 7 October 2022 by Material Tech Company Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Kubota ChemiX Co Ltd

Country of Origin: Japan

Brand: KC

Details of Pipes:

1. 150mm uPVC pipe in grey colour (Class E)
2. 200mm uPVC pipe in grey colour (Class D)

Body Markings:

Size	Body Marking
150mm	∞ PVC-U スイドウ C 氷 (A) (15) JW JIS K6742 · VP150 KC ビニルパイプ
200mm	∞ PVC-U (A) (15) JW JIS K6741 · VP200 KC ビニルパイプ



Expiry Date:

4 March 2026

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only