



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(1098/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

2 November 2022

**Approval of “HENSUN” Stainless Steel Pipe
(General Acceptance No. C20221029)**

Your letters dated 23 September 2022 and 18 October 2022 refer.

Having considered the test report ref. 221982PC220123A issued on 12 October 2022 by Fugro Technical Services Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Hensun Pipe Industry Co Ltd
Country of Origin: the Mainland of China
Brand: Hensun
Details of Pipe: Stainless steel pipe - Series 2 (316L)
Size: 108mm
Body Markings: 佛山市恒合信管业有限公司 O.D 108 * 2.0
AISI 316L / 1.4404 EN10312 : 2002
Expiry Date: 26 June 2027

This Authority hereby permits the use of the above pipe in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only