



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(960/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

9 November 2022

**Approval of “E-CO” Ductile Iron Pipes
(General Acceptance No. C20221054)**

Your letters ref. WSD-ECO-018, WSD-ECO-020 and WSD-ECO-022 dated 8 August 2022, 8 September 2022 and 13 October 2022 respectively refer.

Having considered the test reports ref. BC-SUMMARY-2020-085 and BC-SUMMARY-2020-086 both issued on 12 October 2022 by Castco Testing Centre Limited and WRAS certificates, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Xinxing Ductile Iron Pipes Co Ltd

Country of Origin: the Mainland of China

Brand: E-CO

Details of Pipes: Ductile iron socket and spigot pipes (Class K9 and Class C40) with internal epoxy seal coat (under WRAS approval no. 2111530) for cement mortar lining (under WRAS approval no. 2010531)

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm

Body Markings:

For Class K9:

E-CO DUCTILE IRON PIPE BS EN 545 K9
size x length Zn200

For Class C40:

E-CO DUCTILE IRON PIPE BS EN 545 C40
size x length Zn200**Expiry Date:**

29 July 2025

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only