



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(1120/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

16 November 2022

**Approval of “KING LION” UPVC Pipes
(General Acceptance No. C20221071F)**

Your letter ref. HK/KLSD/LL20/045 dated 28 September 2022 and subsequent submissions received by this department up to 27 October 2022 refer.

Having considered the test report ref. 02341W200013-1 issued on 7 October 2022 by Material Tech Company Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: King Lion PVC Pipes & Fittings MFY Ltd

Country of Origin: the Mainland of China

Brand: King Lion

Details of Pipes: uPVC pipes in white colour (Class E)

Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm

Body Markings: KING LION UPVC PRESSURE PIPE
BS3505 CLASS E size in mm

Expiry Date: 4 September 2027



Proviso:

As the pipes have not been tested for use in contact with water intended for human consumption, the pipes can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above pipes in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in flushing water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only