



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(1141/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

17 November 2022

**Approval of "SUPER FLEX" Settlement Joint
(General Acceptance No. C20221073)**

Your letter ref. GWL/22/0928(NFB-FF450) dated 28 September 2022 and subsequent submissions received by this department up to 28 October 2022 refer.

Having considered the test report ref. BC-SUMMARY-2020-27 issued on 27 March 2020 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Suiken Co Ltd

Country of Origin: Japan

Brand: Super Flex

Details of Fitting: Ductile iron settlement joint with epoxy powder coating under WRAS approval no. 2101521

Model: NFB-FF

Size: 450mm

Body Markings: ト 水 D O ⊗ ||| DNXXX PN16

Expiry Date: 25 March 2025

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



NFB-FF