



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(1049/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

25 November 2022

**Approval of “ZN” Flange Adaptors
(General Acceptance No. C20221095)**

Your letters ref. FAZN.220831, FAZN.221108 and FAZN.221121 dated 31 August 2022, 8 November 2022 and 21 November 2022 respectively refer.

Having considered the test reports ref. PMA23576A issued on 20 October 2022 by ETS-Testconsult Ltd. and ref. 2209447 issued on 21 November 2022 by Qualitech Testing & Consultancy Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Zhong Neng Mechanical Manufacture Co Ltd

Country of Origin: the Mainland of China

Brand: ZN

Details of Fittings: Stainless steel flange adaptor

Model and Size: FA0114-PN16-316L-ZN - 100mm
 FA0168-PN16-316L-ZN - 150mm
 FA0219-PN16-316L-ZN - 200mm
 FA0274-PN16-316L-ZN - 250mm
 FA0326-PN16-316L-ZN - 300mm
 FA0406-PN16-316L-ZN - 400mm
 FA0457-PN16-316L-ZN - 450mm

Body Markings: Brand : ZN Chung Wah Metal Co Ltd Size Pipe OD
 Body : 316L Gland : 316L PN16 Seal : EPDM

Expiry Date: 26 July 2027

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,




(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



FA0114-PN16-316L-ZN / FA0168-PN16-316L-ZN /
FA0219-PN16-316L-ZN / FA0274-PN16-316L-ZN /
FA0326-PN16-316L-ZN / FA0406-PN16-316L-ZN /
FA0457-PN16-316L-ZN