



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(1205/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

6 December 2022

**Approval of “BEL” Ductile Iron Fittings
(General Acceptance No. C20221109)**

Your letters dated 14 October 2022 and 7 November 2022 refer.

Having considered the test reports ref. PMA24436 and PMA24437 both issued on 29 September 2022 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Liaoning Ever Metal Forming Tech Co Ltd

Country of Origin: the Mainland of China

Brand: BEL

Details of Fittings: Ductile iron fittings with epoxy powder coating under WRAS approval no. 2202530

Description	Size (mm)
All Socket Tee	350x350x150
Double Socket Tee with Flanged Branch	350x350x150
All Flanged Tee	350x350x150, 400x400x300, 400x400x400

Description	Size (mm)
Double Flanged Taper	400x200, 400x250, 400x300, 450x250, 450x300, 450x400, 600x400, 600x450

Body Markings:

For All Socket Tee:

BEL BS EN 545 DI K12 size x size

For others:

BEL BS EN 545 DI K12 PN16

1.6-2.4Mpa size x size

Expiry Date:

28 February 2027

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



All Socket Tee



Double Socket Tee with Flanged Branch



All Flanged Tee



Double Flanged Taper