



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(1229/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

6 December 2022

**Approval of “DECO” Ductile Iron Pipe
(General Acceptance No. C20221110)**

Your letters both ref. SL20221019-1 dated 19 October 2022 and 8 November 2022 refer.

Having considered the test report ref. BC-SUMMARY-2022-118 issued on 13 October 2022 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Xinxing Ductile Iron Pipes Co Ltd

Country of Origin: the Mainland of China

Brand: Deco

Details of Pipe: K12 Ductile iron pipe with internal cement mortar lining under WRAS approval no. 2010531

Size: 100mm

Body Markings: DECO DUCTILE IRON PIPE BS EN 545
size x length Class Zn200 K12

Expiry Date: 31 October 2025

This Authority hereby permits the use of the above pipe in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed should be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only