



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/2022 T/J(1201/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

23 December 2022

**Approval of “MASTER BELLOWS, CHINA” Flexible Joints
(General Acceptance No. C20221165)**

Your letter dated 18 October 2022 and subsequent submissions received by this department up to 9 December 2022 refer.

Having considered the test report ref. 220537PC220096A issued on 30 November 2022 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hangzhou Ehase – Flex Co Ltd
Country of Origin: the Mainland of China
Brand: Master Bellows, China
Details of Fitting: Stainless steel flexible joint
Model: MMFF-EH600M
Size: 50mm, 65mm, 80mm, 100mm, 150mm



香港環境卓越大獎



Body Markings:

Master Bellows, China MMFF Size in DN
 Length: 300mm Bellows Lap Joints: SUS316
 Braids: SUS304 Tie Roads Flanges: Carbon Steel
 Flanges to EN1092 PN16

Expiry Date:

7 June 2027

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,




(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



MMFF-EH600M