



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2022 T/J(1391/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 January 2023

**Approval of “MILL-PRO” PE Fittings
(General Acceptance No. C20230022)**

Your letter dated 20 December 2022 refers.

Having considered the test reports ref. PMA25716 and AGA20153 issued on 13 December 2022 and 22 March 2022 by ETS-Testconsult Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhejiang Xinda Plastic Pipe Co Ltd

Country of Origin: the Mainland of China

Brand: Mill-Pro

Details of Fittings: PE fittings in blue colour (PE100, SDR11)

Description	Size (mm)
Equal Tee	250, 315
Reducing Tee	315x315x180

Body Markings:  size in DN PE100 SDR11 Batch No.

Expiry Date: 21 March 2027




This Authority hereby permits the use of the above fittings in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Equal Tee



Reducing Tee