



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 6 ) in WSD 3321/2022 T/J(1166/2022)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

30 January 2023

**Approval of “CSA” Pressure Reducing Valves  
(General Acceptance No. C20230030F)**

Your letters dated 5 October 2022, 7 December 2022 and 28 December 2022 refer.

Having considered the test report ref. J25672A-Dr2 issued 25 November 2022 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** CSA srl  
**Country of Origin:** Italy  
**Brand:** CSA  
**Details of Fittings:** Ductile iron pressure reducing valve  
**Model:** VRCD-M-S  
**Size:** 65mm, 80mm, 100mm, 150mm  
**Body Markings:**  VRCD size in DN → GJS450  
batch number production date (week/year)

**Expiry Date:** 22 March 2026

**Proviso:** As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing systems.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only



VRCD-M-S