



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2022 T/J(1228/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

7 February 2023

**Approval of “EC-LOK” Stainless Steel Fittings
(General Acceptance No. C20230053)**

Your letter ref. 30018/WSD/SUB-7/06 dated 19 October 2022 and subsequent submissions received by this department up to 30 January 2023 refer.

Having considered the test report ref. BC-SUMMARY-2021-144 issued on 8 December 2022 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: EC-LOK Engineering Limited

Country of Origin: the Mainland of China

Brand: EC-LOK

Details of Fittings: Stainless steel fittings with grooved type connection (304)

Description	Size
Coupling	65, 80, 100, 150 (mm)
Male Screw Thread Connector	65x2½", 80x3", 100x4" (mm x inch)
90° Elbow	65, 80, 100, 150 (mm)
45° Elbow	65, 80, 100, 150 (mm)

Description	Size
Equal Tee	65, 80, 100, 150 (mm)
Reducing Tee	80x80x65, 100x100x65, 100x100x80, 150x150x65, 150x150x80, 150x150x100 (mm)
Reducing Tee (With One Press End)	65x65x42, 65x65x54, 80x80x54, 100x100x54 (mm)
Concentric Reducer	80x65, 100x65, 100x80, 150x65, 150x80, 150x100 (mm)
Concentric Reducer (With One Press End)	65x54, 80x35, 80x42, 80x54, 100x54 (mm)

Body Markings: EC-L size - 304

Expiry Date: 5 December 2027

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Coupling



Male Screw Thread Connector



90° Elbow



45° Elbow



Equal Tee



Reducing Tee



Reducing Tee
(With One Press End)



Concentric Reducer



Concentric Reducer
(With One Press End)