



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(1374/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

13 February 2023

**Approval of "SRI" Hydrant Valve
(General Acceptance No. C20230066FS)**

Your letters ref. AWSD0003/22(2) and AWSD0003/22(3) dated 8 December 2022 and 10 January 2023 respectively refer.

Having considered the test report ref. J27516Ar1 issued on 23 November 2022 by Nutek Systems (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Steel Recon Ind Sdn Bhd
Country of Origin: Malaysia
Brand: SRI
Details of Fitting: 80mm Copper alloy twin inlets hydrant valve
Model: DRS095-GM80BSP
Body Markings: **SRI** size
Expiry Date: 11 August 2027

Proviso: The fitting can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fitting in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water fire service systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



DRS095-GM80BSP