



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2022 T/J(1394/2022)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

13 February 2023

**Approval of “MILL-PRO” PE Fittings
(General Acceptance No. C20230067)**

Your letters dated 20 December 2022 and 12 January 2023 refer.

Having considered the test reports ref. PMA25715 and AGA20153A issued on 13 December 2022 and 3 January 2023 by ETS-Testconsult Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhejiang Xinda Plastic Pipe Co Ltd

Country of Origin: the Mainland of China

Brand: Mill-Pro

Details of Fittings: PE fittings in blue colour (PE100, SDR11)

Description	Size (mm)
11.25° Elbow	250
22.5° Elbow	250
45° Elbow	250, 315
90° Elbow	250, 315

Body Markings:  size x angle PE100 SDR11 Batch No.

Expiry Date: 21 March 2027

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



11.25° Elbow



22.5° Elbow



45° Elbow



90° Elbow