



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(33/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

13 March 2023

**Approval of “VALMATIC” Check Valves
(General Acceptance No. C20230143)**

Your letters ref. GWL/23/0112 and GWL/23/0112-R dated 12 January 2023 and 14 February 2023 respectively refer.

Having considered the test report ref. BC-SUMMARY-2022-136 issued on 20 December 2022 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Val-Matic Valve & Manufacturing Corp

Country of Origin: USA

Brand: Valmatic

Details of Fitting: Cast iron globe type silent check valve with epoxy powder coating under WRAS approval no. 2202530

Model and Size:
1825AX005 - 65mm
1803AX006 - 80mm
1804AX006 - 100mm
1806AX006 - 150mm
1808AX005 - 200mm

Body Markings: VALMATIC (Model no.) (DN) PN16 CI

Expiry Date: 28 February 2027

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



1825AX005 / 1803AX006 / 1804AX006 / 1806AX006 / 1808AX005