



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(129/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

31 March 2023

**Approval of “DECO” Ductile Iron Pipes
(General Acceptance No. C20230199)**

Your letters both ref. SL20230214-1 dated 14 February 2023 and 21 March 2023 refer.

Having considered the test reports ref. J28460A-Hr1 issued on 17 March 2023 by Nutek Systems (HK) Ltd. and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Xinxing Ductile Iron Pipes Co Ltd

Country of Origin: the Mainland of China

Brand: Deco

Details of Pipes: K12 Ductile iron pipes with internal cement mortar lining under WRAS approval no. 2010531

Size: 80mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm

Body Markings:

For Size 80mm - 300mm:
DECO DUCTILE IRON PIPE BS EN 545
size x length CLASS Zn200 K12

For Size 350mm - 450mm:
DECO DUCTILE IRON PIPE BS EN 545
size x length CLASS K12

Expiry Date:

31 October 2025

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Mable LH LAM)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only