



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(230/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

4 May 2023

**Approval of "N.U" Stainless Steel Fittings
(General Acceptance No. C20230297)**

Your letter dated 9 March 2023 and subsequent submissions received by this department up to 17 April 2023 refer.

Having considered the test report ref. 212929PC220108A issued on 24 March 2023 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Meide Archung (Jinan) Piping Industry Co Ltd

Country of Origin: the Mainland of China

Brand: N.U

Details of Fittings: Stainless steel fittings with press ends connection (316L)

Description	Model	Size
90° Elbow	90	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108 (mm)
90° Elbow with Plain End	90P	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108 (mm)
90° Elbow with Female Thread	90F	15x½", 22x½", 22x¾", 28x1", 35x1¼", 42x1½", 54x2" (mm x inch)

Description	Model	Size
90° Elbow with Male Thread	90M	15x½", 22x½", 22x¾", 28x1", 35x¾", 35x1¼", 42x1½", 54x2" (mm x inch)
90° Reducing Elbow	90R	22x15, 28x15, 28x22, 35x22, 35x28 (mm)
45° Elbow	120	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108 (mm)
45° Elbow with Plain End	120P	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108 (mm)

Body Markings: N.U 316L AS3688 size

Expiry Date: 9 February 2028

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



90° Elbow



90° Elbow with Plain End




90° Elbow with
Female Thread



90° Elbow with
Male Thread



90° Reducing Elbow



45° Elbow



45° Elbow with Plain End