



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(232/2023)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

4 May 2023

**Approval of "N.U" Stainless Steel Fittings
(General Acceptance No. C20230298)**

Your letter dated 9 March 2023 and subsequent submissions received by this department up to 17 April 2023 refer.

Having considered the test report ref. 212929PC220108(2)B issued on 13 April 2023 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Meide Archung (Jinan) Piping Industry Co Ltd

Country of Origin: the Mainland of China

Brand: N.U

Details of Fittings: Stainless steel fittings with press ends connection (316L)

Description	Model	Size
Straight Coupling	220	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108 (mm)
Coupling with Female Thread	220F	15x $\frac{1}{2}$ ", 22x $\frac{3}{4}$ ", 28x1", 35x1 $\frac{1}{4}$ ", 42x1 $\frac{1}{2}$ ", 54x2" (mm x inch)
Coupling with Male Thread	220M	15x $\frac{1}{2}$ ", 22x $\frac{3}{4}$ ", 28x1", 35x1 $\frac{1}{4}$ ", 42x1 $\frac{1}{2}$ ", 54x2" (mm x inch)

Description	Model	Size
Straight Sleeve Coupling	220K	15, 22, 28, 35, 42, 54, 66.7, 76.1, 108 (mm)
Coupling with Female Joint	220D	15x½", 22x¾", 28x1", 35x1¼", 42x1½", 54x2" (mm x inch)

Body Markings: N.U 316L AS3688 size

Expiry Date: 9 February 2028

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.


c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Straight Coupling



Coupling with Female Thread



Coupling with Male Thread



Straight Sleeve Coupling



Coupling with Female Joint