



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(307/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

5 May 2023

**Approval of “TATA DUCTURA” Ductile Iron Fittings
(General Acceptance No. C20230304)**

Your letters ref. CYH-WSD-0022 and CYH-WSD-0022(R1) dated 24 March 2023 and 18 April 2023 respectively refer.

Having considered the test report ref. BC-SUMMARY-2023-021 issued on 10 February 2023 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tata Metaliks Limited

Country of Origin: the Mainland of China

Brand: Tata Ductura

Details of Fittings: Ductile iron fittings with internal cement mortar lining under WRAS approval no. 1906558

Description	Size (mm)
Double Socket Tee with Flanged Branch	150x150x100, 200x200x150

Body Markings: DUCTURA BS EN 545 DI PN16 (DN) x (DN)

Expiry Date: 30 June 2024

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.


Yours faithfully,



(YAU Hau Yin)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Double Socket Tee with Flanged Branch