



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(360/2023)

Our ref.

來函檔號 :

Your ref.

電話 :

Tel.

傳真 :

Fax.

2824 0578

15 May 2023

**Approval of “MASTER BELLOWS, CHINA” Expansion Joints
(General Acceptance No. C20230322)**

Your letters dated 6 April 2023 and 24 April 2023 refer.

Having considered the test report ref. J28578A-Cr1 issued on 31 March 2023 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hangzhou Ehase-Flex Co Ltd

Country of Origin: the Mainland of China

Brand: Master Bellows, China

Details of Fitting: Stainless steel expansion joint

Model: UNFF 316

Size: 100mm, 150mm, 200mm

Body Markings: Master Bellows, China
UNFF Size: (DN in mm) Length: (in mm)
Bellows, Tube & Lap Joint: SS316
Lateral Movement :(+/- in mm)
Flange to EN1092 PN 16

Expiry Date: 12 February 2028

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.


Yours faithfully,



(YAU Hau Yin)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



UNFF 316