



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(154/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

23 May 2023

**Approval of “GAPEX” PE Pipes
(General Acceptance No. C20230346)**

Your letter ref. GA2K23-L02221-WSD dated 20 February 2023 and subsequent submissions received by this department up to 5 May 2023 refer.

Having considered the test reports ref. PMA25782 and PMA22584A issued on 4 January 2023 and 27 March 2023 by ETS-Testconsult Limited and ref. J24323Ar1 issued on 6 February 2023 by Nutek Systems (HK) Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Fengye Pipe Industrial Co Ltd

Country of Origin: the Mainland of China

Brand: Gapex

Details of Pipes: PE pipes in black colour (PE100, SDR11)

Size: 25mm, 32mm, 40mm, 50mm, 63mm, 90mm, 110mm, 160mm, 250mm

Body Markings: 3731 Gapex DN/OD x wall thickness HDPE
SDR11 PE100 W/P PN16 co-extruded
BS EN12201-2 production date batch no.

Expiry Date: 12 September 2024

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only