



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2023 T/J(431/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

30 May 2023

**Approval of “ACE” Gate Valve
(General Acceptance No. C20230362)**

Your letter ref. WSD/AP-26042023-1 dated 26 April 2023 refers.

Having considered the test report ref. BC-SUMMARY-2023-023 issued on 9 March 2023 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yantai Valve Factory
Country of Origin: the Mainland of China
Brand: ACE
Details of Fitting: Ductile iron metal seated gate valve with epoxy powder coating under WRAS approval no. 2101519
Model: CV-101-S
Size: 450mm
Body Markings: ACE BS EN 1074-2 BS 5163-1 (DN)
PN16 DI CF (Year of manufacture)

Expiry Date:

31 January 2026

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



CV-101-S