



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(455/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

2 June 2023

**Approval of “WATERFRONT” Gate Valves
(General Acceptance No. C20230387)**

Your letters ref. L/23/W246 and L/23/W272 dated 28 April 2023 and 19 May 2023 respectively refer.

Having considered the test report ref. BC-SUMMARY-2023-051 issued on 31 March 2023 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Waterfront Fluid Controls Limited

Country of Origin: the Mainland of China

Brand: Waterfront

Details of Fittings: Ductile iron metal seated gate valve with epoxy powder coating under WRAS approval no. 2008501

Model: Series 263F

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

Body Markings:

(DN) SG SS PN16 BS5163-1 EN1074-2
 (Production Year)

Expiry Date:

31 August 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(YAU Hau Yin)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Series 263F