



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(352/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

12 June 2023

**Approval of “ICV” Check Valves
(General Acceptance No. C20230400)**

Your letters both ref. PDD/OSL/230330/T1 dated 30 March 2023 and 16 May 2023 refer.

Having considered the test reports ref. BC-SUMMARY-2023-029 and 210907-2060 issued on 23 March 2023 and 1 December 2021 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: IC Valves (Nanjing) Co Ltd

Country of Origin: the Mainland of China

Brand: ICV

Details of Fittings: Ductile iron globe type silent check valve with epoxy coating

Model and Size:

903-065-20	- 65mm
903-080-20	- 80mm
903-100-20	- 100mm
903-150-20	- 150mm
903-200-20	- 200mm

Body Markings:

	size in DN	PN16	→	Production Code
←	GLS	Production Code		

Expiry Date: 16 November 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Catlin Kit Wai, Stephen)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



903-065-20 / 903-080-20 / 903-100-20 /
903-150-20 / 903-200-20