



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(358/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

20 June 2023

**Approval of "MRG" Flexible Hoses
(General Acceptance No. C20230441)**

Your letter ref. L23-106 dated 11 April 2023 and subsequent submissions received by this department up to 1 June 2023 refer.

Having considered the test report ref. J28477r1 issued on 25 May 2023 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: MRG SRL

Country of Origin: Italy

Brand: MRG

Details of Fitting: Stainless steel braided inlet flexible hose for tap/mixer

Model: MRG Range

Size: Bore diameter:
6mm

End connection:
M10 male thread x 3/8" captive nut

Bore diameter:
8mm

End connection:
M10 male thread x $\frac{3}{8}$ " captive nut
M10 male thread x $\frac{1}{2}$ " captive nut
M10 long male thread x $\frac{1}{2}$ " captive nut
M12 short male thread x $\frac{1}{2}$ " captive nut
M12 long male thread x $\frac{1}{2}$ " captive nut

Body Marking: Nil

Expiry Date: 15 March 2028

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The inlet flexible hoses are applied for the water tap or mixer connection only and installed in the fresh water plumbing systems."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Catlin Kit Wai, Stephen)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



MRG Range