



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2023 T/J(469/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

21 June 2023

**Approval of “ARON” UPVC Pipes
(General Acceptance No. C20230450F)**

Your letters ref. MH20230505 and MH20230505R1 dated 5 May 2023 and 18 May 2023 respectively refer.

Having considered the test report ref. BC-SUMMARY-2023-048 issued on 3 May 2023 by Castco Testing Centre Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Aron Kasei Co Ltd
Country of Origin: Japan
Brand: Aron
Details of Pipes: uPVC pipes in grey colour (Class E)
Size: 40mm, 50mm, 75mm, 100mm, 150mm

Body Markings:

Model	Size (mm)	Body Marking
VP 40	40	ⒶⓂ JET JIS K 6741 JE0312002 ヲアロソルイコ VP 40 N (Production Date) 01 7 ∞ PVC-U
VP 50	50	ⒶⓂ JET JIS K 6741 JE0312002 ヲアロソルイコ VP 50 N (Production Date) 05 7 ∞ PVC-U
VP 75	75	ⒶⓂ JET JIS K 6741 JE0312002 ヲアロソルイコ VP 75 N (Production Date) 06 7 ∞ PVC-U
VP 100	100	ⒶⓂ JET JIS K 6741 JE0312002 ヲアロソルイコ VP 100 N (Production Date) 06 7 ∞ PVC-U
VP 150	150	ⒶⓂ JET JIS K 6741 JE0312002 ヲアロソルイコ VP 150 N (Production Date) 08 7 ∞ PVC-U

Expiry Date: 29 February 2028

Proviso: As the pipes have not been tested for use in contact with water intended for human consumption, the pipes can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above pipes in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in flushing water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,



(Catlin Kit Wai, Stephen)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only