



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2023 T/J(377/2023)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

30 June 2023

**Approval of "CROWN" uPVC Fittings
(General Acceptance No. C20230471F)**

Your letter ref. uPVC/PF/AL/04023019 dated 17 April 2023 and subsequent submissions received by this department up to 6 June 2023 refer.

Having considered the test report ref. 224211ST230072B issued on 5 June 2023 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangdong Nam Sok Building Material Products Co Ltd

Country of Origin: the Mainland of China

Brand: Crown

Details of Fitting: uPVC fittings in white colour

Description	Size (inch)
Tee	1/2", 3/4", 1", 1 1/4", 1 1/2", 2", 2 1/2", 3", 4"
Female Thread Tee	1/2", 3/4", 1 1/4"
Reducing Tee	3/4"x3/4"x1 1/2", 1"x1"x1 1/2", 1"x1"x3/4", 1 1/4"x1 1/4"x1 1/2", 1 1/4"x1 1/4"x3/4", 1 1/4"x1 1/4"x1", 1 1/2"x1 1/2"x1 1/2", 1 1/2"x1 1/2"x3/4", 1 1/2"x1 1/2"x1", 1 1/2"x1 1/2"x1 1/4", 2"x2"x1 1/2",

Description	Size (inch)
Reducing Tee	2"x2"x $\frac{3}{4}$ ", 2"x2"x1", 2"x2"x1 $\frac{1}{4}$ ", 2"x2"x1 $\frac{1}{2}$ ", 2 $\frac{1}{2}$ "x2 $\frac{1}{2}$ "x1", 2 $\frac{1}{2}$ "x2 $\frac{1}{2}$ "x1 $\frac{1}{4}$ ", 2 $\frac{1}{2}$ "x2 $\frac{1}{2}$ "x1 $\frac{1}{2}$ ", 2 $\frac{1}{2}$ "x2 $\frac{1}{2}$ "x2", 3"x3"x1 $\frac{1}{2}$ ", 3"x3"x2", 4"x4"x2", 4"x4"x3"

Body Markings:

size PVC-U
BS4346 AS1477 code no.

Expiry Date:

2 May 2028

Proviso:

As the fittings has not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing systems.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Ms Winnie LO at tel. no. 3583 4086.

Yours faithfully,

(YAU Hau Yin)


for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Tee



Female Thread Tee



Reducing Tee